BMTRADA

Confirmation of Performance: BMT/MTE/F15022/C

Megrame Medis

Kirtimu Str 37a Vilnius Lithuania

This document confirms that an independent review and calculation has been performed to confirm the whole window U-Value (U_w) for the specification contained in this report. Results were obtained using the following methods:-

- BS EN 673: 2011 Glass in building Determination of thermal transmittance (U value) Calculation method
- BS EN ISO 10077-2: 2012 Thermal performance of windows, doors and shutters Calculation of thermal transmittance Part 2: Numerical method for frames;
- BS EN ISO 10077-1: 2006 Thermal performance of windows, doors and shutters Calculation of thermal transmittance Part 1: General.
 Values for the sample size 1.23m wide x 1.48m high

Product calculated	Vertical sliding sash windows	
Calculation	Technical description	Result
Whole Window U-Value (U _w)	Option 3: Vertical sliding sash window (60mm sashes) with spring balances in sashes and Glazing system 1	1.3 W/(m ^{2.} K)

The legal validity of this report can only be claimed on presentation of the complete report.

Alex Matthews Technical Officer

Ales Da

Michael Chorlton Simulator Tom Gregory
Operations Manager
Issue date: 3 June 2015

BM TRADA

Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND, UK

Tel: 01494 569800 Fax: 01494 564895

Web: www.bmtradagroup.com Email: testing@bmtrada.com

This document is confidential and remains the property of Chiltern International Fire Ltd, trading as BM TRADA





1762